State Maps and Prescriptive Packages

April 2000

The State Maps and Prescriptive Packages contain supporting materials that are needed when using the Envelope and Mechanical Compliance Guides. Insulation and other building envelope requirements and some mechanical system requirements vary by climate. The State Maps divide the United States into 33 different climate zones at a county level. Zones are numbered from 1 through 19 (consistent with the IECC and MEC*check* climate zones) and have a, b, and c designations to reflect climate differences that affect cooling; e.g., cooling degree days and solar radiation. The climate maps are unchanged from Version 1.

To determine the climate zone to use with your building, locate the map for your state and identify the zone number from the legend or county list.

To determine insulation and other building envelope requirements, find the prescriptive package number corresponding to your climate zone. The *Envelope Compliance Guide* employs a package approach that requires all components in your design to meet or exceed the prescribed efficiency levels contained in the prescriptive package. If you find the prescriptive packages too constraining, consider using the COM*check-EZ* software, which allows tradeoffs among building envelope components.

UTAH



Zone	County
14B	Beaver
12B	Box Elder
15	Cache
14B	Carbon
15	Daggett
12B	Davis
15	Duchesne
14B	Emery
14B	Garfield
10B	Grand
12B	Iron
12B	Juab
10B	Kane
13B	Millard
15	Morgan
13B	Piute
15	Rich
12B	Salt Lake
13B	San Juan
14B	Sanpete
13B	Sevier
15	Summit
12B	Tooele
15	Uintah
12B	Utah
15	Wasatch
10B	Washington
14B	Wayne
12B	Weber

Zone 10B
Zone 12B
Zone 13B
Zone 14B
Zone 15

COMcheck-EZ™ Prescriptive Packages Climate Zone 10b

Envelope Component	Low Fenestration Area (0-10% Window-Wall Ratio)			Medium Fenestration Area (10%-25% Window-Wall Ratio)			High Fenestration Area (25%-40% Window-Wall Ratio)			Very High Fenestration Area (40%-50% Window-Wall Ratio)		
Walls (a)	No Framing	Metal Framing	Wood Framing	No Framing	Metal Framing	Wood Framing	No Framing	Metal Framing	Wood Framing	No Framing	Metal Framing	Wood Framing
Framed Any Spacing — *Minimum R-Value*	NA	11	11	NA	11	11	NA	11	11	NA	11	11
CMU, 8 in. or greater with Integral Insulation(b) — *Minimum R-Value*	5	11	11	5	11	11	5	11	11	5	11	11
All Other Masonry Walls(c) — *Minimum R-Value*	5	11	11	5	11	11	5	11	11	5	11	11
Windows	No Projection	³.25 Projection	³.5 Projection	No Projection	³.25 Projection	³.5 Projection	No Projection	³.25 Projection	³.5 Projection	No Projection	³.25 Projection	³.5 Projection
Maximum Solar Heat Gain Coefficient	Any	Any	Any	0.5	0.6	0.7	0.4	0.5	0.6	0.3	0.4	0.5
Maximum U-Factor	Any	Any	Any	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5
Skylight (Limit 3% of Roof Area)												
Maximum U-Factor		0.8			0.8			0.8			0.8	
Roof	Continuous Insulation	or	Roof Cavity Insulation	Continuous Insulation	or	Roof Cavity Insulation	Continuous Insulation	or	Roof Cavity Insulation	Continuous Insulation	or	Roof Cavity Insulation
All-Wood Joist/Truss — *Minimum R-Value*	17		19	19		25	19		25	19		25
Nonwood Joist/Truss — *Minimum R-Value*	18		25	20		25	20		25	20		25
Concrete Slab or Deck — *Minimum R-Value*	17		NA	19		NA	19		NA	19		NA
Metal Purlin with Thermal Break — *Minimum R-Value*	18		30	20		30	20		30	20		30
Metal Purlin without Thermal Break — *Minimum R-Value*	18		X	20		X	20		X	20		30
Floor	Continuous Insulation	or	Cavity Insulation	Continuous Insulation	or	Cavity Insulation	Continuous Insulation	or	Cavity Insulation	Continuous Insulation	or	Cavity Insulation
All-Wood Joist/Truss — *Minimum R-Value*	12		19	12		19	12		19	12		19
Nonwood Joist/Truss — *Minimum R-Value*	13		19	13		19	13		19	13		19
Concrete Slab or Deck — *Minimum R-Value*	13		NA	13		NA	13		NA	13		NA
Slab Edge or Basement Walls	Insulation			Insulation			Insulation			Insulation		
Minimum R-Value	0			0			0			0		

Notes:

(a) For walls next to unconditioned spaces, use the Low Fenestration Area wall requirements.

(b) Integral insulation in concrete masonry units may be perlite, vermiculite, or other insulating material. Minimum R-values are in addition to insulation in CMU voids.

(c) Use of the Other Masonry Walls category is restricted to walls weighing 35 lb/ft2 or more; lightweight masonry veneers and unfilled CMUs <8 in. in thickness do not qualify.

- "NA" indicates the category is not applicable.
- A minimum R-value of zero indicates no insulation is required.
- "Any" indicates any available product will comply.
- "X" indicates no complying option exists in the prescriptive packages.

COMcheck-EZ™ Prescriptive Packages Climate Zone 12b

Envelope Component	Low Fenestration Area (0-10% Window-Wall Ratio)				Medium Fenestration Area (10%-25% Window-Wall Ratio)				High Fenestration Area (25%-40% Window-Wall Ratio)				Very High Fenestration Area (40%-50% Window-Wall Ratio)			
Walls (a,b)	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing
Framed *Minimum Cavity R-Value (c)*	NA		11	11	NA		11	11	NA		11	11	NA		13	13
Any Spacing *Minimum Continuous R-Value (d)*	NA		0	0	NA		0	0	NA		0	0	NA		3	0
CMU, 8 in. or greater *Minimum Cavity R-Value*	NA		11	11	NA		11	11	NA		11	11	NA		11	11
with Integral Insulation(e) *Minimum Continuous R-Value*	5		0	0	5		0	0	5		0	0	5		0	0
All Other *Minimum Cavity R-Value*	NA		11	11	NA		11	11	NA		11	11	NA		11	11
Masonry Walls(f) *Minimum Continuous R-Value*	5		0	0	5		0	0	5		0	0	5		0	0
Windows	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection
Maximum Solar Heat Gain Coefficient	Any		Any	Any	0.5		0.6	0.7	0.4		0.5	0.6	0.3		0.4	0.5
Maximum U-Factor	Any		Any	Any	0.6		0.6	0.6	0.5		0.5	0.5	0.5		0.5	0.5
Skylight (Limit 3% of Roof Area)																
Maximum U-Factor			0.8				0.8				0.8				0.8	
Roof	Continuous Insulation	or	Roof Cavity Insulation		Continuous Insulation	or	Roof Cavity Insulation		Continuous Insulation	or	Roof Cavity Insulation		Continuous Insulation	or	Roof Cavity Insulation	
All-Wood Joist/Truss *Minimum R-Value*	16		19		19		25		23		30		23		30	
Nonwood Joist/Truss *Minimum R-Value*	17		25		20		25		24		30		24		30	
Concrete Slab or Deck *Minimum R-Value*	16		NA		19		NA		23		NA		23		NA	
Metal Purlin with Thermal Break *Minimum R-Value*	17		25		20		30		24		X		24		38	
Metal Purlin without Thermal Break *Minimum R-Value*	17		X		20		X		24		X		24		49	
Floor	Continuous Insulation	or	Cavity Insulation		Continuous Insulation	or	Cavity Insulation		Continuous Insulation	or	Cavity Insulation		Continuous Insulation	or	Cavity Insulation	
All-Wood Joist/Truss *Minimum R-Value*	15		19		15		19		15		19		15		19	
Nonwood Joist/Truss *Minimum R-Value*	16		19		16		19		16		19		16		19	
Concrete Slab or Deck *Minimum R-Value*	16		NA		16		NA		16		NA		16		NA	
Slab Edge or Basement Walls	Insulation				Insulation				Insulation				Insulation			
Minimum R-Value	0				0				8				8			

Notes:

(a) For walls next to unconditioned spaces, use the Low Fenestration Area wall requirements.

(b) Where values are shown for both cavity and continuous insulation, both requirements must be met.

(c) Cavity insulation is insulation between framing members or furring strips and does not refer to integral insulation in CMUs.

(d) Continuous insulation is insulation that is continuous across structural members, and its effectiveness is undimished by compression or bridging.

(e) Integral insulation in concrete masonry units may be perlite, vermiculite, or other insulating material. Minimum R-values are in addition to insulation in CMU voids.

(f) Use of the Other Masonry Walls category is restricted to walls weighing 35 lb/ft2 or more; lightweight masonry veneers and unfilled CMUs <8 in. in thickness do not qualify.

- "NA" indicates the category is not applicable.
- A minimum R-value of zero indicates no insulation is required.
- "Any" indicates any available product will comply.
- "X" indicates no complying option exists in the prescriptive packages.

COMcheck-EZ™ Prescriptive Packages Climate Zone 13b

Envelope Component	Low Fenestration Area (0-10% Window-Wall Ratio)			Medium Fenestration Area (10%-25% Window-Wall Ratio)			High Fenestration Area (25%-40% Window-Wall Ratio)			Very High Fenestration Area (40%-50% Window-Wall Ratio)		
Walls (a,b)	No Framing	Metal Framing	Wood Framing	No Framing	Metal Framing	Wood Framing	No Framing	Metal Framing	Wood Framing	No Framing	Metal Framing	Wood Framing
Framed *Minimum Cavity R-Value (c)*	NA	13	11	NA	13	11	NA	13	11	NA	13	13
Any Spacing *Minimum Continuous R-Value (d)*	NA	0	0	NA	0	0	NA	0	0	NA	7	3
CMU, 8 in. or greater *Minimum Cavity R-Value*	NA	11	11	NA	11	11	NA	11	11	NA	11	11
with Integral Insulation(e) *Minimum Continuous R-Value*	5	0	0	5	0	0	5	0	0	5	0	0
All Other *Minimum Cavity R-Value*	NA	11	11	NA	11	11	NA	11	11	NA	11	11
Masonry Walls(f) *Minimum Continuous R-Value*	5	0	0	5	0	0	5	0	0	5	0	0
Windows	No Projection	[3].25 Projection	[3].5 Projection	No Projection	[3].25 Projection	[3].5 Projection	No Projection	[3].25 Projection	[3].5 Projection	No Projection	[3].25 Projection	[3].5 Projection
Maximum Solar Heat Gain Coefficient	Any	Any	Any	0.5	0.6	0.7	0.4	0.5	0.6	0.4	0.5	0.6
Maximum U-Factor	Any	Any	Any	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4
Skylight (Limit 3% of Roof Area)												
Maximum U-Factor		0.8			0.8			0.8			0.8	
Roof	Continuous Insulation	or	Roof Cavity Insulation	Continuous Insulation	or	Roof Cavity Insulation	Continuous Insulation	or	Roof Cavity Insulation	Continuous Insulation	or	Roof Cavity Insulation
All-Wood Joist/Truss *Minimum R-Value*	18		25	19		25	23		30	23		30
Nonwood Joist/Truss *Minimum R-Value*	19		25	20		25	24		30	24		30
Concrete Slab or Deck *Minimum R-Value*	18		NA	19		NA	23		NA	23		NA
Metal Purlin with Thermal Break *Minimum R-Value*	19		30	20		30	24		X	24		38
Metal Purlin without Thermal Break *Minimum R-Value*	19		X	20		X	24		X	24		49
Floor	Continuous Insulation	or	Cavity Insulation	Continuous Insulation	or	Cavity Insulation	Continuous Insulation	or	Cavity Insulation	Continuous Insulation	or	Cavity Insulation
All-Wood Joist/Truss *Minimum R-Value*	17		19	17		19	17		19	17		19
Nonwood Joist/Truss *Minimum R-Value*	17		25	17		25	17		25	17		25
Concrete Slab or Deck *Minimum R-Value*	17		NA	17		NA	17		NA	17		NA
Slab Edge or Basement Walls	Insulation			Insulation			Insulation			Insulation		
Minimum R-Value	0			0			8			8		

Notes:

(a) For walls next to unconditioned spaces, use the Low Fenestration Area wall requirements.

(b) Where values are shown for both cavity and continuous insulation, both requirements must be met.

(c) Cavity insulation is insulation between framing members or furring strips and does not refer to integral insulation in CMUs.

(d) Continuous insulation is insulation that is continuous across structural members, and its effectiveness is undimished by compression or bridging.

(e) Integral insulation in concrete masonry units may be perlite, vermiculite, or other insulating material. Minimum R-values are in addition to insulation in CMU voids.

(f) Use of the Other Masonry Walls category is restricted to walls weighing 35 lb/ft2 or more; lightweight masonry veneers and unfilled CMUs <8 in. in thickness do not qualify.

- "NA" indicates the category is not applicable.
- A minimum R-value of zero indicates no insulation is required.
- "Any" indicates any available product will comply.
- "X" indicates no complying option exists in the prescriptive packages.

COMcheck-EZ™ Prescriptive Packages Climate Zone 14b

Envelope Component	Low Fenestration Area (0-10% Window-Wall Ratio)				Medium Fenestration Area (10%-25% Window-Wall Ratio)				High Fenestration Area (25%-40% Window-Wall Ratio)				Very High Fenestration Area (40%-50% Window-Wall Ratio)			
Walls (a,b)	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing
Framed *Minimum Cavity R-Value (c)*	NA		13	11	NA		13	11	NA		13	11	NA		13	13
Any Spacing *Minimum Continuous R-Value (d)*	NA		3	0	NA		3	0	NA		3	0	NA		7	3
CMU, 8 in. or greater *Minimum Cavity R-Value*	NA		11	11	NA		11	11	NA		11	11	NA		11	11
with Integral Insulation(e) *Minimum Continuous R-Value*	5		0	0	5		0	0	5		0	0	5		0	0
All Other *Minimum Cavity R-Value*	NA		11	11	NA		11	11	NA		11	11	NA		11	11
Masonry Walls(f) *Minimum Continuous R-Value*	5		0	0	5		0	0	5		0	0	5		0	0
Windows	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection
Maximum Solar Heat Gain Coefficient	Any		Any	Any	0.5		0.6	0.7	0.4		0.5	0.6	0.4		0.5	0.6
Maximum U-Factor	0.7		0.7	0.7	0.5		0.5	0.5	0.5		0.5	0.5	0.4		0.4	0.4
Skylight (Limit 3% of Roof Area)																
Maximum U-Factor			0.8				0.8				0.8				0.8	
Roof	Continuous Insulation	or		Roof Cavity Insulation	Continuous Insulation	or		Roof Cavity Insulation	Continuous Insulation	or		Roof Cavity Insulation	Continuous Insulation	or		Roof Cavity Insulation
All-Wood Joist/Truss *Minimum R-Value*	19			25	19			25	23			30	23			30
Nonwood Joist/Truss *Minimum R-Value*	20			25	20			25	24			30	24			30
Concrete Slab or Deck *Minimum R-Value*	19			NA	19			NA	23			NA	23			NA
Metal Purlin with Thermal Break *Minimum R-Value*	20			30	20			30	24			X	24			38
Metal Purlin without Thermal Break *Minimum R-Value*	20			X	20			X	24			X	24			49
Floor	Continuous Insulation	or		Cavity Insulation	Continuous Insulation	or		Cavity Insulation	Continuous Insulation	or		Cavity Insulation	Continuous Insulation	or		Cavity Insulation
All-Wood Joist/Truss *Minimum R-Value*	19			25	19			25	19			25	19			25
Nonwood Joist/Truss *Minimum R-Value*	19			25	19			25	19			25	19			25
Concrete Slab or Deck *Minimum R-Value*	19			NA	19			NA	19			NA	19			NA
Slab Edge or Basement Walls	Insulation				Insulation				Insulation				Insulation			
Minimum R-Value	0				8				8				8			

Notes:

(a) For walls next to unconditioned spaces, use the Low Fenestration Area wall requirements.

(b) Where values are shown for both cavity and continuous insulation, both requirements must be met.

(c) Cavity insulation is insulation between framing members or furring strips and does not refer to integral insulation in CMUs.

(d) Continuous insulation is insulation that is continuous across structural members, and its effectiveness is undimished by compression or bridging.

(e) Integral insulation in concrete masonry units may be perlite, vermiculite, or other insulating material. Minimum R-values are in addition to insulation in CMU voids.

(f) Use of the Other Masonry Walls category is restricted to walls weighing 35 lb/ft2 or more; lightweight masonry veneers and unfilled CMUs <8 in. in thickness do not qualify.

- "NA" indicates the category is not applicable.
- A minimum R-value of zero indicates no insulation is required.
- "Any" indicates any available product will comply.
- "X" indicates no complying option exists in the prescriptive packages.

COMcheck-EZ™ Prescriptive Packages Climate Zone 15

Envelope Component	Low Fenestration Area (0-10% Window-Wall Ratio)				Medium Fenestration Area (10%-25% Window-Wall Ratio)				High Fenestration Area (25%-40% Window-Wall Ratio)				Very High Fenestration Area (40%-50% Window-Wall Ratio)			
Walls (a,b)	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing	No Framing	or	Metal Framing	or Wood Framing
Framed *Minimum Cavity R-Value (c)*	NA		13	11	NA		13	11	NA		13	11	NA		13	13
Any Spacing *Minimum Continuous R-Value (d)*	NA		3	0	NA		3	0	NA		3	0	NA		7	4
CMU, 8 in. or greater *Minimum Cavity R-Value*	NA		11	11	NA		11	11	NA		11	11	NA		13	11
with Integral Insulation(e) *Minimum Continuous R-Value*	5		0	0	5		0	0	5		0	0	5		0	0
All Other *Minimum Cavity R-Value*	NA		11	11	NA		11	11	NA		13	11	NA		13	11
Masonry Walls(f) *Minimum Continuous R-Value*	5		0	0	5		0	0	6		0	0	6		3	0
Windows	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection	No Projection		[3].25 Projection	[3].5 Projection
Maximum Solar Heat Gain Coefficient	Any		Any	Any	0.5		0.6	0.7	0.5		0.6	0.7	0.4		0.5	0.7
Maximum U-Factor	0.7		0.7	0.7	0.5		0.5	0.5	0.4		0.4	0.4	0.4		0.4	0.4
Skylight (Limit 3% of Roof Area)																
Maximum U-Factor	0.6				0.6				0.6				0.6			
Roof	Continuous Insulation	or	Roof Cavity Insulation		Continuous Insulation	or	Roof Cavity Insulation		Continuous Insulation	or	Roof Cavity Insulation		Continuous Insulation	or	Roof Cavity Insulation	
All-Wood Joist/Truss *Minimum R-Value*	19		25		19		25		23		30		23		30	
Nonwood Joist/Truss *Minimum R-Value*	20		25		20		25		24		30		24		30	
Concrete Slab or Deck *Minimum R-Value*	19		NA		19		NA		23		NA		23		NA	
Metal Purlin with Thermal Break *Minimum R-Value*	20		30		20		30		24		X		24		38	
Metal Purlin without Thermal Break *Minimum R-Value*	20		X		20		X		24		X		24		NA	
Floor	Continuous Insulation	or	Cavity Insulation		Continuous Insulation	or	Cavity Insulation		Continuous Insulation	or	Cavity Insulation		Continuous Insulation	or	Cavity Insulation	
All-Wood Joist/Truss *Minimum R-Value*	22		25		22		25		22		25		22		25	
Nonwood Joist/Truss *Minimum R-Value*	23		30		23		30		23		30		23		30	
Concrete Slab or Deck *Minimum R-Value*	22		NA		22		NA		22		NA		22		NA	
Slab Edge or Basement Walls	Insulation				Insulation				Insulation				Insulation			
Minimum R-Value	0				8				8				8			

Notes:

(a) For walls next to unconditioned spaces, use the Low Fenestration Area wall requirements.

(b) Where values are shown for both cavity and continuous insulation, both requirements must be met.

(c) Cavity insulation is insulation between framing members or furring strips and does not refer to integral insulation in CMUs.

(d) Continuous insulation is insulation that is continuous across structural members, and its effectiveness is undimished by compression or bridging.

(e) Integral insulation in concrete masonry units may be perlite, vermiculite, or other insulating material. Minimum R-values are in addition to insulation in CMU voids.

(f) Use of the Other Masonry Walls category is restricted to walls weighing 35 lb/ft2 or more; lightweight masonry veneers and unfilled CMUs <8 in. in thickness do not qualify.

- "NA" indicates the category is not applicable.
- A minimum R-value of zero indicates no insulation is required.
- "Any" indicates any available product will comply.
- "X" indicates no complying option exists in the prescriptive packages.